

# G4K

## Fixed PQ Analyzer

# BLACKBOX

# Datasheet



## THE FUTURE OF POWER QUALITY

- Continuous Waveform Recordings
- Superior Accuracy
- Threshold Free Setup

Date: October 2013

SMX-1108-0100

Document Version: V1.2

IN THIS DOCUMENT

- I. Input Characteristics..... 3
- II. BLACKBOX Web Interface Display ..... 4
- III. Measurement Range, Resolution & Accuracy..... 10
- IV. Measurement Method..... 12
- V. General Specifications..... 15
- VI. PQZIP Recording ..... 17
- VII. Physical ..... 18
- VIII. Dimensional View..... 19
  - VIII.1 G4410..... 19
  - VIII.2 G4420 & G4430 ..... 19
- IX. Multi IO Module ..... 20
  - IX.1 Physical ..... 22
  - IX.2 Dimensional View..... 22
    - IX.2.1 Expansion Option A - G4K With One Multi I/O Module..... 22
    - IX.2.2 Expansion Option B - G4K With Two Multi I/O Modules ..... 22

## I. Input Characteristics

VOLTAGE INPUTS	G4410	G4420	G4430
Number of Inputs	AC: 4 (3 Phase & Neutral)	AC: 4 (3 Phase & Neutral)	AC: 4 (3 Phase & Neutral)
Maximum Input Voltage ( $V_{RMS}$ )	1KV	1KV	1KV
Nominal Voltage Range ( $V_{RMS}$ )	110 to 690V	110 to 690V	110 to 690V
Maximum Peak Measurement Voltage ( $V_{pk}$ )	8kV	8kV	8kV
Input Impedance	3M $\Omega$	3M $\Omega$	3M $\Omega$
Bandwidth	6.25kHz	12.5kHz	25kHz
Nominal Frequency	42.5 to 69Hz	42.5 to 69Hz	42.5 to 69Hz
CURRENT INPUTS	G4410	G4420	G4430
Number of Inputs	AC: 4 (3 Phase & Neutral)	AC: 4 (3 Phase & Neutral)	AC: 4 (3 Phase & Neutral)
Nominal Full Scale ( $I_{RMS}$ )	5A	5A	5A
Maximum Peak Measurement ( $I_{pk}$ )	50A	50A	50A
Range	0 to 50A	0 to 50A	0 to 50A
Burden	0.1mVA @ 5A	0.1mVA @ 5A	0.1mVA @ 5A
Bandwidth	6.25kHz	6.25kHz	6.25kHz
SAMPLING SYSTEM	G4410	G4420	G4430
Maximum Sampling Rate for Each Channel Simultaneously:			
Voltage	256 Samples/Cycle	512 Samples/Cycle	1024/512 Samples/Cycle
Current	256 Samples/Cycle	256 Samples/Cycle	256/512 Samples/Cycle
Type of Analog to Digital Converter	16/20 <sup>1</sup> Bit	16/20 <sup>1</sup> Bit	16/20 <sup>1</sup> Bit
Resolution	Dual Range Gain of 2 x 16 Bit on 8 Channels		
PLL Synchronization	1024 Samples on 10/12 Cycles According IEC61000-4-7		

<sup>1</sup> Effective Bit

II. BLACKBOX Web Interface Display

REAL-TIME DATA

Total Measurements

Available in Monitoring >> Summary

Summary		<input type="checkbox"/> PU
Frequency	62.002 Hz	
I <sub>avg</sub>	0.5000 A	
V(LL) <sub>avg</sub>	207.80 V	
V(LN) <sub>avg</sub>	119.98 V	
Power factor <sub>total</sub>	1.0000	
Phase Order	123	
Synchronization Status		
Time Synchronization	Main	Good
DSP Synchronization	On	

Summary

- Frequency
- Current (Current Single Phase System/ Current Averaged Over All 3 Phases in 3 Phase System)
- Line to Line Voltage (Averaged Over All 3 Phases)
- Line to Neutral Voltage (Averaged Over All 3 Phases)
- Total System Power Factor (Over 3 Phases)
- Phase Order (Voltage Phase Order From V1 Moving Clockwise)

Synchronization Status

- Time Synchronization
- DSP Synchronization

10/12 Cycles

Available in Monitoring >> Voltage & Current

V/I	RMS	Min Value	Max Value	THD	Crest Factor	K Factor
V <sub>12</sub>	403.1893 V	381.5403 V	420.2249 V	1.713893 %	1.448701	---
V <sub>23</sub>	404.3133 V	383.9400 V	421.8228 V	1.821636 %	1.450176	---
V <sub>31</sub>	403.2043 V	383.6008 V	420.2467 V	1.614527 %	1.447160	---
I <sub>1</sub>	97.64386 A	43.89695 A	728.5047 A	7.002274 %	1.432072	1.295215
I <sub>2</sub>	53.23956 A	17.21198 A	719.1996 A	14.46074 %	1.779383	1.805157
I <sub>3</sub>	62.10047 A	32.43429 A	342.1426 A	12.28039 %	1.704414	1.499499
I <sub>12</sub>	20.71540 A	10.81033 A	114.0386 A	12.27157 %	1.703125	1.493802
I <sub>23</sub>	32.34406 A	14.63008 A	242.8318 A	7.073332 %	1.430983	1.288402
I <sub>31</sub>	51.18102 A	24.85549 A	290.8023 A	7.955546 %	1.502144	1.298753

According to IEC 61000-4-30. Minimum, Maximum & Average Values of:

- RMS (Voltage & Current)
- THD (Voltage & Current)
- Crest Factor (Voltage & Current)
- K Factor (Current)
- TDD (Current)
- THD Even/Odd (Voltage & Current)
- Over/Under Deviation (Voltage)
- Unbalance (Voltage & Current)

150/180 Cycles, 10 Minutes, 2 Hours Aggregation

Available in Monitoring >> Average

Frequency			
FrequencyOver 10 sec		50.03945 Hz	
Averages			
	150/180 Cycles	10 Min.	2 Hours
Timestamp	09/09/2010 19:17:25	09/09/2010 19:10:00	09/09/2010 18:00:00
Flag	Not flagged	Not flagged	Not flagged
V <sub>12</sub>	398.5608 V	399.0757 V	403.1885 V
Under-deviation			
	150/180 Cycles	10 Min.	2 Hours
V <sub>12</sub>	0.364090 %	0.214424 %	0.000000 %
Over-deviation			

According to IEC 61000-4-30:

- Frequency 10 Seconds
- RMS (Voltage)
- Over/Under Deviation (Voltage)
- Unbalance (Voltage & Current)

Power

Available in Monitoring >> Power

Power Summary					
	Active Power	Reactive Power	Apparent Power	True PF	Displacement PF
Phase 1	2.564086 kW	4.930077 kVAr	5.556996 kVA	0.461416 (Ind)	0.469361 (Ind)
Phase 2	5.637701 kW	-5.262132 kVAr	7.711919 kVA	0.731037 (Cap)	0.736560 (Cap)
Phase 3	12.74040 kW	2.974239 kVAr	13.08296 kVA	0.973816 (Ind)	0.982176 (Ind)
Total	20.94219 kW	2.642184 kVAr	26.35188 kVA	0.794713 (Ind)	0.469361 (Ind)

Per Phase & Total:

- Active Power
- Reactive power
- Apparent Power
- True Power Factor
- Displacement Power Factor

## REAL-TIME DATA

### Temperature

Available in Monitoring >> Temperature

Internal Temperature		
Internal <sub>avg</sub>	Internal <sub>min</sub>	Internal <sub>max</sub>
60.60 °C	59.05 °C	62.45 °C

External Temperature		
External <sub>avg</sub>	External <sub>min</sub>	External <sub>max</sub>
No PT100	No PT100	No PT100


PSU Temperature		
PSU <sub>avg</sub>	PSU <sub>min</sub>	PSU <sub>max</sub>
63.34 °C	61.66 °C	65.31 °C

Displays Average, Minimum & Maximum Values of:

- Internal Temperature (DSP Module)
- External Temperature (Outside via PT100)
- PSU Temperature (Power Supply Module)

### Phasor

Available in Monitoring >> Phasors



Shows Real Time Phasor Diagram:


- Voltage & Current (Depending on the Power Configuration. Select Combinations - Phase to Phase, Phase to Line Voltage & Current)
- Normalize (Vector Part of the Largest Vector)
- Amplitude (Per Phasor)
- Angle (Relative to V1/V12 - Depending on the Network Topology)

Exportable to: MetaFile, BMP, JPG, PNG, Text/Data

### Waveform Display

Graph / Table / Both

Available in Monitoring >> Waveform



Captures Waveforms Up To 11 Channels - By:

- Cycle Selection (1 to 4 Cycles)
- Voltage & Current (Depending on Power Configuration: Select Combinations - Phase to Phase, Phase to Line Voltage & Current)

Exportable to: MetaFile, BMP, JPG, PNG, Text/Data

### Voltage Flickering

Available in Monitoring >> Voltage Flickering

Voltage Flickering								
	PST INST	PSST 10 Sec.	PST 10 Min.	SPLT 1 Hour	PLT 2 Hour	LPLT 10 Hour	LPLT 1 Day	LPLT 7 Day
V <sub>1</sub>	10.694	12.638	26.264	20.857	34.566	31.996	32.853	29.096
V <sub>2</sub>	11.654	12.307	30.969	22.285	31.198	32.767	34.068	30.159
V <sub>3</sub>	7.9501	9.0571	23.860	21.445	31.429	22.055	21.030	22.535
V <sub>12</sub>	318.25	268.67	182.70	182.70	182.52	182.70	182.70	182.66
V <sub>23</sub>	15.679	14.188	15.666	15.329	15.269	15.629	15.608	15.638
V <sub>31</sub>	13.006	12.329	19.446	17.396	16.226	19.749	18.349	18.386

10 Min.		
Timestamp	28/10/2012 15:30:00	
Flag	Flagged: V1,V2,V3	

2 Hours		
Timestamp	28/10/2012 14:00:00	
Flag	Flagged: V1,V2,V3	

Aggregation:


- PSTINST to PST 2 Seconds (Instantaneous Flicker Evaluation)
- PSST 10 Seconds (As per PSST Averaged over 10 Seconds)
- PST 10 Minutes (According to IEC61000-4-15, Short Term Flicker Evaluation)
- SPLT - PLT 1 Hour
- PLT 2 Hours (According to IEC61000-4-15, Long Term Flicker Evaluation)
- LPLT 10 Hours (P<sub>LT</sub> Averaged over 10 Hours)
- LPLT 1 Day (P<sub>LT</sub> Averaged over 1 Day)
- LPLT 7 Days (P<sub>LT</sub> Averaged over 7 Days)

## REAL-TIME DATA

### Pinst Waveform

Graph / Table / Both

Available in Monitoring >> Pinst Waveforms



Displays Voltage Instantaneous Flicker Waveforms

Exportable to: MetaFile, BMP, JPG, PNG, Text/Data

### Minimum / Maximum Flickering

Available in Monitoring >> Min/Max Flickering

Min/Max Flickering								
	PSST 2 Sec.	PSST 10 Sec.	PST 10 Min.	SPLT 1 Hour	PLT 2 Hour	LPLT 10 Hour	LPLT 1 Day	LPLT 7 Day
V <sub>12</sub>	Min.	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Max.	71637.10	23127.63	124.9797	1.194570	0.950628	0.580950	0.478969
V <sub>23</sub>	Min.	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Max.	70519.79	22767.93	124.8582	1.407181	1.182908	0.780778	0.654229
V <sub>31</sub>	Min.	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Max.	71572.71	23106.75	125.2780	1.350298	1.109859	0.752893	0.624114


Displays Minimum / Maximum Short & Long Term Voltage Flickering Values:

- PST INST - PST 2 Seconds (Instantaneous Flicker Evaluation)
- PSST 10 Seconds (As per PSST Averaged over 10 Seconds)
- PST 10 Minutes (According to IEC61000-4-15, Short Term Flicker Evaluation)
- SPLT - PLT 1 Hour
- PLT 2 Hours (According to IEC61000-4-15, Long Term Flicker Evaluation)
- LPLT 10 Hours ( $P_{LT}$  Averaged over 10 Hours)
- LPLT 1 Day ( $P_{LT}$  Averaged over 1 Day)
- LPLT 7 Days ( $P_{LT}$  Averaged over 7 Days)

### Voltage & Current Harmonics

Bar Graph / Table / Both

Available in Monitoring >> V&I Harmonics



According to IEC61000-4-7:

- 10/12 Cycles Harmonics & Inter-Harmonics (Voltage & Current)
- 150/180 Cycles Harmonic & Inter-Harmonics (Voltage Only)
- 10 Minutes Harmonics & Inter-Harmonics (Voltage Only)
- 2 Hours Harmonics & Inter-Harmonics (Voltage Only)
- Harmonic Angles (Voltage & Current)

Harmonics Display:


- Real Values
- Values Relative to the Fundamental Harmonic

Exportable to: MetaFile, BMP, JPG, PNG, Text/Data

### Power Harmonics

Bar Graph / Table / Both

Available in Monitoring >> P&Q Harmonics



According to IEC61000-4-7:

- Active Power Harmonics
- Reactive Power Harmonics

Exportable to: MetaFile, BMP, JPG, PNG, Text/Data




## REAL-TIME DATA

### Spectrum

Bar Graph / Table / Both

Available in Monitoring >> Spectrum



### Voltage & Current Spectrum Display:

- Harmonics Relative to the First Harmonic up to 11 Channels
- Exportable to: MetaFile, BMP, JPG, PNG, Text/Data

### Harmonics Table

Available in Monitoring >> Harmonics Table

V & I Harmonics												
	V <sub>1</sub>	V <sub>2</sub>	V <sub>3</sub>	V <sub>4</sub>	V <sub>5</sub>	V <sub>6</sub>	V <sub>7</sub>	V <sub>8</sub>	V <sub>9</sub>	V <sub>10</sub>	V <sub>11</sub>	V <sub>12</sub>
H <sub>1</sub>	0.035 V	0.024 V	0.043 V	0.002 V	0.011 V	0.019 V	0.008 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>2</sub>	0.004 V	0.003 V	0.004 V	0.004 V	0.002 V	0.002 V	0.002 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>3</sub>	0.002 V	0.002 V	0.003 V	0.003 V	0.003 V	0.002 V	0.003 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>4</sub>	0.016 V	0.012 V	0.018 V	0.001 V	0.005 V	0.007 V	0.002 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>5</sub>	0.002 V	0.001 V	0.004 V	0.005 V	0.002 V	0.003 V	0.004 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>6</sub>	0.006 V	0.004 V	0.006 V	0.003 V	0.002 V	0.003 V	0.004 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>7</sub>	0.004 V	0.003 V	0.005 V	0.002 V	0.003 V	0.002 V	0.003 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>8</sub>	0.003 V	0.003 V	0.002 V	0.001 V	0.002 V	0.002 V	0.003 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>9</sub>	0.004 V	0.006 V	0.006 V	0.002 V	0.002 V	0.003 V	0.003 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>10</sub>	0.001 V	0.002 V	0.003 V	0.002 V	0.002 V	0.003 V	0.003 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>11</sub>	0.003 V	0.001 V	0.002 V	0.005 V	0.002 V	0.001 V	0.001 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>12</sub>	0.003 V	0.003 V	0.002 V	0.005 V	0.002 V	0.002 V	0.001 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A
H <sub>13</sub>	0.002 V	0.003 V	0.003 V	0.004 V	0.002 V	0.002 V	0.002 V	0.0 A	0.0 A	0.0 A	0.0 A	0.0 A

According to IEC61000-4-7:

- 10/12 Cycles Harmonics & Inter-Harmonics (Voltage & Current)
- 150/180 Cycles Harmonic & Inter-Harmonics (Voltage Only)
- 10 Minutes Harmonics & Inter-Harmonics (Voltage Only)
- 2 Hours Harmonics & Inter-Harmonics (Voltage Only)
- Harmonic Angles (Voltage & Current)

Harmonics Display:

- Real Values
- Values Relative to the Fundamental Harmonic

### V/I, Minimum & Maximum Harmonics Table

Available in Monitoring >> V/I Min/Max Harmonics

Harmonics Min & Max												
	V <sub>1</sub>	V <sub>2</sub>	V <sub>3</sub>	V <sub>4</sub>	V <sub>5</sub>	V <sub>6</sub>	V <sub>7</sub>	V <sub>8</sub>	V <sub>9</sub>	V <sub>10</sub>	V <sub>11</sub>	V <sub>12</sub>
H <sub>1</sub>	Min. 0°	0°	0°	0°	0°	0°	0°	0°	0°	0°	0°	0°
H <sub>2</sub>	Min. 90.54°	90.32°	90.77°	90.62°	90.52°	90.49°	90.31°	90.3°	90.17°	90.17°	90.17°	90.17°
H <sub>3</sub>	Min. -179.21°	-178.99°	-179.16°	-179.64°	-179.73°	-179.25°	-179.14°	-179.8°	-179.82°	-179.74°	-179.74°	-179.74°
H <sub>4</sub>	Min. -89.93°	-89.78°	-89.94°	-89.73°	-89.52°	-89.75°	-89.82°	-89.92°	-89.63°	-89.58°	-89.58°	-89.58°
H <sub>5</sub>	Min. 1.76°	3.88°	6.37°	0.35°	0.68°	0.37°	0.62°	0.21°	0.28°	0.18°	0.18°	0.18°
H <sub>6</sub>	Min. -0.43°	-1.79°	-2.95°	-1.84°	-0.75°	-0.58°	-0.61°	-2.45°	-2.12°	-2.24°	-2.24°	-2.24°

Summarizes V/I Minimum / Maximum Harmonic Values:

- Harmonic Angles (Voltage & Current)
- Harmonic Amplitude Values (Voltage & Current)

### PQ Minimum & Maximum Harmonics Table

Available in Monitoring >> V/I Min/Max Harmonics

P & Q min-max harmonics												
	P <sub>1</sub>	P <sub>2</sub>	P <sub>3</sub>	P <sub>4</sub>	P <sub>5</sub>	P <sub>6</sub>	P <sub>7</sub>	P <sub>8</sub>	P <sub>9</sub>	P <sub>10</sub>	P <sub>11</sub>	P <sub>12</sub>
1	Min. -0.084122 kW	-0.010523 kW	-0.018131 kW	-0.000111 kW	-0.598618 kVar	-0.191277 kVar	-0.115993 kVar					
2	Min. 1.499689 kW	1.499878 kW	1.513583 kW	0.000101 kW	0.599336 kVar	0.189146 kVar	0.082963 kVar					
3	Min. -0.001169 kW	-0.002675 kW	-0.019172 kW	-0.000003 kW	-0.003728 kVar	-0.005166 kVar	-0.017188 kVar					
4	Min. 0.005582 kW	0.006626 kW	0.008249 kW	0.000004 kW	0.004161 kVar	0.004809 kVar	0.002695 kVar					
5	Min. -0.002878 kW	-0.000327 kW	-0.000634 kW	-0.000037 kW	-0.004361 kVar	-0.007889 kVar	-0.000565 kVar					
6	Min. 1.498993 kW	1.498402 kW	1.498557 kW	0.000019 kW	0.043294 kVar	0.004553 kVar	0.120384 kVar					
7	Min. -0.000449 kW	-0.000361 kW	-0.000891 kW	-0.000006 kW	-0.000576 kVar	-0.000191 kVar	-0.000626 kVar					
8	Min. 0.000833 kW	0.000473 kW	0.001512 kW	0.000006 kW	0.000645 kVar	0.000156 kVar	0.000843 kVar					
9	Min. -0.000222 kW	-0.000057 kW	-0.000335 kW	-0.000001 kW	-0.000248 kVar	-0.000119 kVar	-0.000291 kVar					
10	Min. 0.000516 kW	0.00031 kW	0.000544 kW	0.000001 kW	0.000236 kVar	0.000095 kVar	0.000548 kVar					
11	Min. -0.000041 kW	-0.000053 kW	-0.000362 kW	-0.000001 kW	-0.000186 kVar	-0.000081 kVar	-0.000069 kVar					
12	Min. 0.000408 kW	0.000202 kW	0.00082 kW	0.000001 kW	0.000245 kVar	0.000068 kVar	0.000389 kVar					

According to IEC61000-4-7:

- Active Power Harmonics
- Reactive Power Harmonics

## ENERGY DATA

### Consumption & Demand Table

[Available in Energy >> Consumption & Demand](#)

Consumption & Demand			
	Net Consumption	Demand	Peak Demand
Active Energy	42.822 kWh	0.0000 kW	4.5549 kW
Reactive Energy	-1.4878 kVAh	0.0000 kVA	-1.8135 kVA
Apparent Energy	43.248 kVAh	0.0000 kVA	4.5590 kVA

Summary Amount & Makeup of the Net Energy (Received & Delivered):

- Net Consumption
- Demand
- Peak Demand

Energy Flow:

- Active Energy (Real Energy in kWh)
- Reactive Energy (Volt Amperes Reactive Energy in kVAh)
- Apparent Energy (Volt Amperes Reactive Energy in kVAh & Energy kVAh)

### Detailed Information Table

[Available in Energy >> Detailed Information](#)

Received Energy				
	Current Period	Total Consumption	Demand	Peak Demand
Active Energy	0.0000 kWh	0.0205 kWh	0.0000 kW	0.0168 kW
Reactive Energy	0.0000 kVAh	27.657 kVAh	0.0000 kVA	0.0001 kVA
Delivered Energy				
	Current Period	Total Consumption	Demand	Peak Demand
Active Energy	0.0000 kWh	5.0917 kWh	0.0016 kW	0.0040 kW
Reactive Energy	0.0000 kVAh	0.1067 kVAh	0.0000 kVA	0.0793 kVA
Net Energy (Received-Delivered)				
	Current Period	Total Consumption	Demand	Peak Demand
Active Energy	0.0000 kWh	-5.0712 kWh	-0.0016 kW	0.0128 kW
Reactive Energy	0.0000 kVAh	-27.550 kVAh	0.0000 kVA	-0.0792 kVA
Net Generated Energy (Delivered-Received)				
	Current Period	Total Consumption	Demand	Peak Demand
Active Energy	0.0000 kWh	5.0712 kWh	0.0016 kW	-0.0128 kW
Reactive Energy	0.0000 kVAh	-27.550 kVAh	0.0000 kVA	0.0792 kVA
Total Energy (Received+Delivered)				
	Current Period	Total Consumption	Demand	Peak Demand
Active Energy	0.0000 kWh	5.1122 kWh	0.0016 kW	0.0207 kW
Reactive Energy	0.0000 kVAh	27.764 kVAh	0.0000 kVA	0.0793 kVA
Apparent Energy	0.0000 kVAh	31.405 kVAh	0.0010 kVA	0.5056 kVA

Detailed Amount & Makeup of the Energy Flow:

- Current Period
- Total Consumption
- Demand
- Peak Demand

Energy:

- Received Energy (Active & Reactive)
- Delivered Energy (Active & Reactive)
- Generated Energy (Active & Reactive)
- Net Energy, Received & Delivered (Active & Reactive)
- Total Energy, Received & Delivered (Active, Reactive & Apparent)

### Measurement Status Summary Table

[Available in Energy >> Measurement Status](#)

Status Summary	
Started	23/05/2012 12:31:36 UTC
Last Start	23/09/2012 05:37:46 UTC
Up Time	155:4:25:30 D:H:M:S
Down Time	2:14:45:32 D:H:M:S
Availability	98.342857 %
Energy Interval	1 min
External Sync	Disable
Sliding Window	Enable

Summary with Additional Statistics & Context on Energy:

- Started (Date & time stamp when the Energy Meter was originally activated for the very first time)
- Last Start (Date & Time Stamp from the Last Energy Meter Reset)
- Up Time (Total Cumulative Operational Time of Energy Meter Since Last Start)
- Down Time (Total Cumulative Time Energy Meter was Inoperative)
- Availability (Actual Operational Time of Energy Meter)
- Energy (Metering) Interval
- Sliding Window (Averaging System In Use):
- Enable (Energy is Calculated Using Sliding Interval for Each Energy Meter)
- Disable (Energy is Calculated Using Fixed Interval for Each Energy Meter)



## POWER QUALITY DATA

### Compliance Summary Table

[Available in Power Quality >> Summary](#)

Event Status		Compliance Summary	
Voltage Frequency	OK	Compliance Type	EN50160
Supply Voltage Variations	OK	Running Status	Running
Rapid Voltage Changes	OK	Embedded Report	None
Supply Voltage Dips	FAIL	Evaluation Status	OK
Short Interruptions	OK	Start Time	***
Long Interruptions	OK	Window Time On	7:0:34:15 D.H.M.S
Temporary Overvoltage	OK	Window Time Off	0:0:0:0 D.H.M.S
Flicker Severity	OK	Measurement Flag	Flagged V1,V2,V3
Harmonic Voltage	OK		
Supply Voltage Unbalance	OK		

Compliance Standard Status & Summary:

- Event Status (Pass / Fail)
- Compliance Summary

**Built in Multi-standard compliance, with support for EN50160 & other National Standards:**

[Available in Configuration >> PQ Compliance](#)

### Compliance Info Table

[Available in Power Quality >> Information](#)

Detailed Compliance Info							Compliance Status: Running
	Status	Observation	Window Interval	Time OK	Time Fail	Time N/A	Total Events
Voltage Frequency	OK	Complete	1 week	100.000 %	0.0000 %	0.0000 %	0
Supply Voltage Variations	OK	Complete	1 week	100.000 %	0.0000 %	0.0000 %	0
Rapid Voltage Changes	OK	Complete	1 week	100.000 %	0.0000 %	0.0000 %	0
Supply Voltage Dips	FAIL	Complete	1 week	97.647 %	0.0000 %	0.0000 %	4583
Short Interruptions	FAIL	Complete	1 week	96.498 %	0.0000 %	0.0000 %	5
Long Interruptions	FAIL	Complete	1 week	97.675 %	0.0000 %	0.0000 %	2
Temporary Overvoltage	OK	Complete	1 week	100.000 %	0.0000 %	0.0000 %	10623
Flicker Severity	OK	Complete	1 week	100.000 %	0.0000 %	0.0000 %	0
Harmonic Voltage	OK	Complete	1 week	100.000 %	0.0000 %	0.0000 %	0
Supply Voltage Unbalance	OK	Complete	1 week	100.000 %	0.0000 %	0.0000 %	0

Supplies Detailed Compliance Info:


- Compliance Criteria
- PQ Compliance

**Built in Multi Standard Compliance, with support for EN50160 & other National Standards:**

[Available in Configuration >> PQ Compliance](#)

### Compliance Chart

[Available in Power Quality >> Chart](#)



Displays Compliance Levels (Equals to % of Time OK):

- PQ Compliance

Exportable to: MetaFile, BMP, JPG, PNG, Text/Data

### Events

[Available in Power Quality >> Events](#)

Start at	0	Page Size	10	Time	UTC	Copy log to clipboard
Logged Events						
#	Event Timestamp	Code	Detailed Event Data			
0	25/09/2010 08:00:01	242	PQ Voltage Flickering: 1.241312 (24.121054[dev%]) 7200.000000[sec] Severity:22 Phases Delta 3 wires: 23.31)			
1	27/09/2010 10:00:00	242	PQ Voltage Flickering: 1.054226 (5.419522[dev%]) 7200.000000[sec] Severity:20 Phases Delta 3 wires: 23.31)			
2	26/09/2010 22:44:53	244	PQ Rapid Voltage Changes: 5.990278[%] (5.957037[dev%]) 2.997351 [sec] Severity:37 Phases Delta 3 wires: 12.23.31)			
3	26/09/2010 22:44:53	235	PQ Voltage Dips: 355.140625[V] (11.181641[dev%]) 0.059910[sec] Severity:52 Phases Delta 3 wires: 23.31)			
4	26/09/2010 06:00:00	242	PQ Voltage Flickering: 1.074149 (7.373047[dev%]) 7200.000000[sec] Severity:20 Phases Delta 3 wires: 23.31)			
5	24/09/2010 10:10:56	233	PQ Frequency Out of Range: 49.494373[Hz] (0.976563[dev%]) 10.000000[sec] Severity:130 Phases Delta 3 wires: )			

Displays Log of Configured PQ Events

**Configurable EN50160/Compliance Events (DIP/SWELL/V-Interruptions)**

[\(Available in Configuration >> PQ Compliance\)](#)

III. Measurement Range, Resolution & Accuracy

VOLT/AMPS/HERTZ	MEASUREMENT RANGE	RESOLUTION	ACCURACY
V <sub>RMS</sub> (AC & DC)	0 to 900V	0.01V	±0.1% of Nominal Voltage <sup>1</sup>
A <sub>RMS</sub>	1 to 5A	0.1mA	±0.1% of Nominal Current
V <sub>pk</sub>	8KV	10mV	±0.1% from Reading
Voltage Crest Factor	1<	0.01	Better than 0.5%
Current Crest Factor	1<	0.01	Better than 0.5%
Hz to 50Hz Nominal	42.5 to 62Hz	10mHz	±5mHz
Hz to 60Hz Nominal	51 to 69Hz	10mHz	±5mHz
K-Factor	0<	0.01	±0.25%
DIPS, SWELLS & INTERRUPTIONS	MEASUREMENT RANGE	RESOLUTION	ACCURACY
V <sub>RMS</sub> ½ (AC & DC)	0 to 900V	0.01V	±0.2% of Nominal Voltage
Duration	HHH,MM,SS,MMM	Half Cycle	One Cycle
Threshold Levels	Programmable Thresholds & Hysteresis in Percentage of Nominal Voltage Event Detection Based Upon ½ Cycle RMS Voltages Captures Dips, Swells, Interruptions & Rapid Voltage Changes		
VOLTAGE HARMONICS	MEASUREMENT RANGE	RESOLUTION	ACCURACY
Harmonic Order	1 to 50 Grouping: Harmonic Subgroups According to IEC61000-4-7		
Inter-Harmonic Order	1 to 50 Grouping: Inter-Harmonic Subgroups According to IEC61000-4-7		
THD <sub>(n=50)</sub>	0 to 100%	0.01%	±0.25%
THD Even	0 to 100%	0.01%	±0.25%
THD Odd	0 to 100%	0.01%	±0.25%
Hz (Spectrum)	0 to 3174Hz	fSys 10/12	±5%
Phase Angle	-180 to +180°	0.01°	±0.01°

<sup>1</sup> For Nominal Voltage 80 to 690V

POWER & ENERGY	MEASUREMENT RANGE	RESOLUTION	ACCURACY
Active Power	$\pm 5\text{kW} \times \text{CT Ratio} \times \text{PT Ratio}$	10mW	$\pm 0.2\%$
Reactive Power	$\pm 5\text{kVAr} \times \text{CT Ratio} \times \text{PT Ratio}$	10mVAR	$\pm 2\%$
Apparent Power	$\pm 5\text{kVA} \times \text{CT Ratio} \times \text{PT Ratio}$	10mVA	$\pm 0.2\%$
Active Energy	$\pm 5\text{kWh} \times \text{CT Ratio} \times \text{PT Ratio}$	10mWh	$\pm 0.2\%$
Reactive Energy	$\pm 5\text{kVArh} \times \text{CT Ratio} \times \text{PT Ratio}$	10mVArh	$\pm 2\%$
Apparent Energy	$\pm 5\text{kVAh} \times \text{CT Ratio} \times \text{PT Ratio}$	10mVAh	$\pm 0.2\%$
True Power Factor	$\pm 1$ (CAP\IND)	10 $\mu$	$\pm 0.2\%$
Displacement Power Factor	$\pm 1$ (CAP\IND)	10 $\mu$	$\pm 0.2\%$
FLICKERING	MEASUREMENT RANGE	RESOLUTION	ACCURACY
$P_{\text{SST}}$ , $P_{\text{ST}}$ 10 Minutes, $S_{\text{PLT}}$ , $P_{\text{LT}}$ 2 Hours, $L_{\text{PLT}}$	0 to 20	0.01	$\pm 5\%$
$P_{\text{ST\_INST}}$	0 to 20	0.01	$\pm 8\%$
UNBALANCE	MEASUREMENT RANGE	RESOLUTION	ACCURACY
Volts (Negative & Zero Seq.) Ratio	0 to 100%	0.1%	0.15%
Current (Negative & Zero Seq.) Ratio	0 to 100%	0.1%	0.5%
TRANSIENT CAPTURE			ACCURACY
Minimum Detection Duration			78.1 $\mu\text{s}$ (G4410)
			39 $\mu\text{s}$ (G4420)
			19.5 $\mu\text{s}$ (G4430)

## IV. Measurement Method

$V_{RMS}$	$V_{RMSx} = \sqrt{\sum_{n=1} ((V \cos \varphi)^2 + (V \sin \varphi)^2)}$ <p> <math>n</math> = Number of Samples  <math>x</math> = Specific Channel  10/12 Continuous Non-Overlapping Cycles  In Accordance with IEC61000-4-30 </p>
$V_{RMS1/2}$ , $A_{RMS1/2}$	Value Is Measured Over 1 Cycle, Commencing At a Fundamental Zero Crossing, & Refreshed Each Half-Cycle. This Technique Is Independent For Each Channel In Accordance With IEC61000-4-30
$A_{RMS}$	$I_{RMSx} = \sqrt{\sum_{n=1} ((I \cos \varphi)^2 + (I \sin \varphi)^2)}$ <p> <math>n</math> = Number of Samples  <math>x</math> = Specific Channel  10/12 Continuous Non-Overlapping Cycles  In Accordance with IEC61000-4-30 </p>
$H_{RMS}$	$H_{RMSx} = \sqrt{\sum_{n=2} ((A \cos \varphi)^2 + (A \sin \varphi)^2)}$ <p> <math>n</math> = Number of Samples  <math>x</math> = Specific Channel  10/12 Continuous Non-Overlapping Cycles  In Accordance with IEC61000-4-30 </p>
$V_{pk}$ , $I_{pk}$	Absolute Highest Sample Value Within 10/12 Cycle Interval
V Crest Factor	$\frac{V_{pk}}{V_{RMS}}$ <p>Measures Ratio Between the <math>V_{pk}</math> and <math>V_{RMS}</math></p>
A Crest Factor	$\frac{I_{pk}}{I_{RMS}}$ <p>Measures ratio between the <math>I_{pk}</math> &amp; <math>A_{RMS}</math></p>
Hz	$\frac{\text{Complete cycles in 10 seconds}}{10 \text{ seconds}}$ <p>Measured Every 10 Seconds in Accordance with IEC61000-4-30</p>
THD	$\sqrt{\frac{\sum_{n=2}^{50} C_n^2}{C_1^2}}$ <p> <math>C</math> = Harmonic RMS Value  <math>n</math> = Harmonic Order </p>
THD Even	$\sqrt{\frac{\sum_1^{25} C_{2n}^2}{C_1^2}}$ <p> <math>C</math> = Harmonic RMS Value  <math>n</math> = Harmonic Order </p>
THD Odd	$\sqrt{\frac{\sum_1^{25} C_{2n+1}^2}{C_1^2}}$ <p> <math>C</math> = Harmonic RMS Value  <math>n</math> = Harmonic Order </p>

Harmonics	$G_{sg,n}^2 = \sum_{i=1}^1 C_{k+i}^2$ In Accordance With IEC61000-4-7																									
Inter-Harmonics	In Accordance With IEC61000-4-7																									
Watt	$P = V_{h_1} * I_{h_1} * \cos(\varphi_1) + \sum_n V_{h_n} * I_{h_n} * \cos(n * \varphi_1 + \varphi_n)$  $n = 2 \text{ to } 50$																									
VA	$S = V_{RMS} * I_{RMS}$																									
VAR	$Q = \sqrt{S^2 - P^2}$																									
True Power Factor (PF)	$PF_{sign} = P_{sign} * Q_{sign}$ <i>if <math>PF_{sign} &gt; 0</math> than IND; <math>PF_{sign} &lt; 0</math> than CAP</i> <table><tr><th>QUADRAT</th><th>P</th><th>Q</th><th>PF</th><th>PF UNIT</th></tr><tr><td>I</td><td>+</td><td>+</td><td>+</td><td>IND</td></tr><tr><td>II</td><td>-</td><td>+</td><td>-</td><td>CAP</td></tr><tr><td>III</td><td>-</td><td>-</td><td>+</td><td>IND</td></tr><tr><td>IV</td><td>+</td><td>-</td><td>-</td><td>CAP</td></tr></table>	QUADRAT	P	Q	PF	PF UNIT	I	+	+	+	IND	II	-	+	-	CAP	III	-	-	+	IND	IV	+	-	-	CAP
QUADRAT	P	Q	PF	PF UNIT																						
I	+	+	+	IND																						
II	-	+	-	CAP																						
III	-	-	+	IND																						
IV	+	-	-	CAP																						
Displacement Power Factor (PF)	Same as True PF, But Only With Fundamental Components:  $true\ PF = \left  \frac{P_{h1}}{S_{h1}} \right $ , if $Q > 0$ than CAP; if $Q < 0$ than IND																									
Unbalance	The Supply Voltage Unbalance is Evaluated Using the Method of Symmetrical Components in Accordance with IEC61000-4-30																									
Zero Sequence Unbalance	$U_0 = \left  \frac{u_0}{u_1} \right  * 100$																									
Negative Sequence Unbalance	$U_2 = \left  \frac{u_2}{u_1} \right  * 100$																									
Positive Sequence	Defined as the symmetrical vector system derived by application of the Fortescue's transformation matrix, and that rotates in the same direction as the power frequency voltage (or current):  $\underline{U}_1 = \frac{1}{3} (\underline{U}_a + a^1 \underline{U}_b + a^2 \underline{U}_c)$ where $a = 1 \angle 120^\circ = -\frac{1}{2} + j \frac{\sqrt{3}}{2}$  and $\underline{U}_a, \underline{U}_b, \underline{U}_c$ and are line to neutral voltages (fundamental component)  In Accordance With IEC61000-3-13, ed. 1.0 (2008-02) Ref: 3.26.3																									
Negative Sequence	Defined as the symmetrical vector system derived by application of the Fortescue's transformation matrix, and that rotates in the opposite direction to the power frequency voltage (or current):  $\underline{U}_2 = \frac{1}{3} (\underline{U}_a + a^2 \underline{U}_b + a^1 \underline{U}_c)$ where $a = 1 \angle 120^\circ = -\frac{1}{2} + j \frac{\sqrt{3}}{2}$  and $\underline{U}_a, \underline{U}_b, \underline{U}_c$ and are line to neutral voltages (fundamental component)  In Accordance With IEC61000-3-13, ed. 1.0 (2008-02) Ref: 3.26.4																									

Zero Sequence	<p>Defined as the in-phase symmetrical vector system derived by application of the Fortescue's transformation matrix:</p> $\underline{U}_0 = \frac{1}{3} (\underline{U}_a + \underline{U}_b + \underline{U}_c)$ <p>where <math>\underline{U}_a</math>, <math>\underline{U}_b</math>, <math>\underline{U}_c</math> and are line to neutral voltages (fundamental component)</p> <p>In Accordance With IEC61000-3-13, ed. 1.0 (2008-02) Ref: 3.26.5</p>
Flicker	Five Block Digital Flickermeter as Described in IEC 61000-4-15 Edition 2. Functional & Design Specification Includes 230V/50Hz, 230V/60Hz, 120V/50Hz, 120V/60Hz Lamp Models
Flicker $P_{INST}$ (Instantaneous Term Flicker Evaluation)	Output of Block 5 of the Flickermeter in Accordance with IEC61000-4-15 Edition 2
Flicker $P_{ST}$ (Short Term Flicker Evaluation)	<p>The Standard Measurement Time For <math>P_{ST}</math> is 10 Minutes:</p> $P_{ST} = \sqrt{0.0314P_{0.1} + 0.0525P_{1s} + 0.0657P_{3s} + 0.28P_{10s} + 0.08P_{50s}}$ <p>Where the Percentiles <math>P_{0.1}</math>, <math>P_1</math>, <math>P_3</math>, <math>P_{10}</math>, <math>P_{50}</math> are the Flicker Levels Exceeded for 0.1, 1, 3, 10 &amp; 50% of the Time During The Observation Period. The Suffix "s" in the Formula Indicates that the Smoothed Value Should be Used. The Smoothed Values are Obtained Using the Following Formulas:</p> $P(1s) = (P(.7) + P(1) + P(1.5))/3$ $P(3s) = (P(2.2) + P(3) + P(4))/3$ $P(10s) = (P(6) + P(8) + P(10) + P(13) + P(17))/5$ $P(50s) = (P(30) + P(50) + P(80))/3$
Flicker $P_{LT}$ (Long Term Flicker Evaluation)	<p>The Long-Term <math>P_{LT}</math> is Derived From the Short-Term Values Over 12 Short-Term Values of 10 Minutes Each Over a Period of 2 hours:</p> $P_{LT} = \sqrt[3]{\frac{\sum_{i=1}^N P_{STi}^3}{N}}$ <p>Where <math>P_{STi}</math> (<math>i = 1, 2, 3, \dots</math>) are the Consecutive Readings of the <math>P_{ST}</math></p>
K-Factor	$\frac{\sum_{n=1}^{25} (i_n * n)^2}{\sum_{n=1}^{25} i_n^2}$ <p>Where <math>n</math> is the Harmonic #, and <math>i_n</math> is the RMS value of the <math>n^{TH}</math> Harmonic</p>



V. General Specifications

STORAGE CAPACITY		G4410	G4420	G4430
Internal Memory		128MB	4GB	16GB
REAL-TIME (SELF SYNCHRONIZATION)				
Real Time Clock		± 1 Second per 24 Hours		
Time Synchronization		Optional GPS/SNTP/IRIGB/DCF-77 time sync module provides time uncertainty better than 100µs. When synchronization becomes unavailable, Time Tolerance is 1 second per day.		
DEVICE SYNCHRONIZATION ACCURACY				
GPS & PPS		Better than 100µs		
IRIG B <sup>1</sup>		100 to 200µs		
DCF-77		±15ms		
SNTP Server		50 to 100µs		
COMMUNICATION				
CONTROL				
Web Server		Comprehensive web server for local & remote real-time monitoring & control		
FTP Server		Standard protocol for main storage memory		
PORTS		G4410	G4420	G4430
Ethernet Ports		1	2	2
RS485/422		1	1	1
LAN 1				
Baud Rate		10/100MBit		
Communication Protocols		Modbus TCP, OPC, DNP3, TELNET & SMTP Client		
Connector Type		RJ45 Female With Led Indicators		
Power Over Ethernet (PoE- In)		1 (Available as Input - 13 Watt, DC: 48V)		
LAN 2				
Baud Rate		10/100MBit		
Communication Protocols		Modbus TCP, OPC, DNP3, TELNET & SMTP Client		
Connector Type		RJ45 Female With Led Indicators		
Power Over Ethernet (PoE- Out)		1 (Available as Output - 13 Watt, DC: 48V)		
RS485/422 CONNECTION				
Baud Rate		Configurable: 1200 / 2400 / 4800 / 9600 / 14400 / 19200 / 38400 57600 / 115200		
Communication Protocols		Modbus RTU, PPP & TTY		
Duplex		Full		
Maximum Cable Length		15.2m (50')		

<sup>1</sup> Only if Multi I/O Module is present

APPLICABLE STANDARDS	
Measurement Standards	EN50160, IEEE1159, IEEE519, IEC61000-4-15, IEC61000-4-7, IEC61000-4-30 Class A, IEC62053-22/23 Class 0.2
EMC Standards	EN55011 Group 1 Class A, EN60439-1 (Clauses 7.9.1, 7.9.3, 7.9.4, 7.10.3, 7.10.4), FCC Part 15 Subpart B Class A, IEC61000-3-3, EN61000-6-2, IEC60255
Environmental Standards	IEC60068-2-1, 2, 6, 11, 27, 30, 75
Safety Standards	EN61010-1:2001 2 <sup>ND</sup> Edition
POWER SUPPLY	
Power Over Ethernet (PoE- In) <sup>1</sup>	According to 802.3af
Operating Range	AC: 100 to 260V @ 50/60Hz DC: 100 to 300V
Auxiliary AC Supply	DC: 48V
Low Voltage Ride Through	Up to 25 Seconds

<sup>1</sup> G4420 & G4430 Units Only

## VI. PQZIP Recording

METHOD			
PQZIP compression technology which enables continuous gap-less <sup>1</sup> recording of all electrical parameters-related data for a significant time duration without the need of event thresholds of any kind. Events, Flicker and Energy are non-compressed parameters.			
WAVEFORM	G4410	G4420	G4430
Voltage Sampling per Cycle	256	512	1024/512
Current Sampling per Cycle	256	256	256/512
Recording Time	1 Day Continuous Recording at a Fixed Ratio Mode of 3GB/Month	3 Months Continuous Recording at a Fixed Ratio Mode of 1.2GB/Month	1 & Year Continuous Recording at a Fixed Ratio Mode of 1.2GB/Month
EVENTS			
Memory	Up to 12K Event Logs		
FLICKER PST	G4410	G4420	G4430
Recording Interval	10 Minutes	10 Minutes	10 Minutes
Recording Time	1 Day Continuous Recording at a Fixed Ratio Mode of 3GB/Month	3 Months Continuous Recording at a Fixed Ratio Mode of 1.2GB/Month	1 & Year Continuous Recording at a Fixed Ratio Mode of 1.2GB/Month
ENERGY	G4410	G4420	G4430
Energy Interval	1, 2, 5, 10, 15, 30 & 60 Minutes	1, 2, 5, 10, 15, 30 & 60 Minutes	1, 2, 5, 10, 15, 30 & 60 Minutes
Recording Time	1 Day Continuous Recording at a Fixed Ratio Mode of 3GB/Month	3 Months Continuous Recording at a Fixed Ratio Mode of 1.2GB/Month	1 & Year Continuous Recording at a Fixed Ratio Mode of 1.2GB/Month


<sup>1</sup> 99.9% of the Time

VII. Physical


PHYSICAL	
Dimensions	175mm x 232mm x137.5mm (6.88” x 9.13” x 5.41”)
Weight	1.7Kg (3.74Lb)
ENVIRONMENTAL	
Design	Sleek black, shock proof, easy install, with Multi I/O extension option
Drip and Dust Proof	IP20 according to IEC60529 when used in tilt stand position
Shock and Vibration	Shock 30g, Vibration: 3g Sinusoid, Random 0.03 g2/Hz according to MIL-PRF-28800F Class 2
Operating Temperature	-20 to 70° C (-4 to 158° F)
Storage Temperature	-40 to 85° C (-40 to 185° F)
Humidity	85%
Maximum Operating Altitude	2Km (1.24Mi)
Warranty	One Year
TEMPERATURE SENSORS	
External Temperature Sensor (PT100)	-40 to 90° C (-40 to 210° F)
Internal PSU Temperature Sensor	Informative
Internal DSP Temperature Sensor	Informative

## VIII. Dimensional View

### VIII.1 G4410



### VIII.2 G4420 & G4430



## IX. Multi IO Module

DIGITAL INPUTS	
Channels	8
Sampling	800Hz @ 50Hz 960Hz @ 60Hz
Range	3 DC Options Ranging From 0 to 220V: <ul style="list-style-type: none"><li>▪ 3.3V, <math>V_{in} &lt; 48V</math></li><li>▪ <math>&lt;48</math> to 110V</li><li>▪ <math>&lt;110</math> to 220V (Requires Additional Resistor)</li></ul>
Pulse Type	KYZ, 0->1->0, 1->0->1
Isolation Connector	125V
DIGITAL OUTPUTS	
Channels	4
Maximum Switching Voltage	AC: 35V; DC: 45V
Pulse Type	KYZ, 0->1->0, 1->0->1
ANALOG INPUTS	
Channels	4
Sampling Rate	2Hz
Signal	4-20mA (Continuous DC)
Impedance	25 $\Omega$
Maximum Voltage (Common Mode)	270V
ANALOG OUTPUTS	
Channels	4
Signal	4-20mA (Continuous DC)
Accuracy	0.1% (10 Bit D to A Resolution)
RELAY OUTPUT MODULE	
Channels	3 x Change Over
Contact Configuration	1 CO (SPDT - Single Pole Double Throw)
Rated Voltage	AC: 250V
Maximum Switching Voltage	AC: 400V
Maximum Current	AC: 5A/250V; 10A/110V DC: 5A/30V
Maximum Peak Current	15A
Rated Current	6A
Operating Time	4ms
Release Time	6ms
Maximum Reaction Time	10ms
Maximum Drop-out Time	4ms
Output Resistance	50M $\Omega$



## RS232 CONNECTIONS

Baud Rate	Configurable: 1200 / 2400 / 4800 / 9600 / 14400 / 19200 / 38400 57600 / 115200
Duplex	Full
Supported Protocols	GPS
Connector Type	DB9 Male
Maximum Cable Length	15.2m (500')


IX.1 Physical

PHYSICAL

Dimensions	
Expansion Option A - One Module	175mm x 232mm x 137.5mm (6.88" x 9.13" x 5.41")
Expansion Option B - Two Modules	175mm x 232mm x 171mm (6.88" x 9.13" x 6.73")
Weight	
Expansion Option A - One Module	1.8Kg (3.96Lb)
Expansion Option B - Two Modules	1.9Kg (4.18Lb)

IX.2 Dimensional View

IX.2.1 Expansion Option A - G4K With One Multi I/O Module



IX.2.2 Expansion Option B - G4K With Two Multi I/O Modules

